



BRANZ Appraised
Appraisal No.487 [2012]

BRANZ Appraisals

**Technical Assessments of products
for building and construction**

**BRANZ
APPRAISAL
No. 487 (2012)**

This Appraisal replaces BRANZ
Appraisal No. 487 (2006) dated
21 December 2006.

**ULLTRACLAD®
CAVITY SYSTEM**

Ullrich Aluminium Co Ltd.
PO Box 98 843
South Auckland Mail Centre
Manukau City

Tel: 0800 500 338
Fax: 09 262 6256


BRANZ
BRANZ Limited
Private Bag 50 908
Porirua City
New Zealand
Tel: +64 4 237 1170
Fax: +64 4 237 1171
www.branz.co.nz



Product

1.1 The Ulltraclad® Cavity System is a cavity-based, inter-locking powder coated aluminium weatherboard system. It is designed to be used as an external wall cladding system for residential and light commercial type buildings where domestic construction techniques are used.

1.2 The system includes horizontally fixed Ulltraclad® weatherboards (Standard, Baby Corro, Tee Board, Vertical Plank, Traditional and Shadoline), timber battens, internal and external corner mouldings, starter strips, board jointers, board locators, joinery flashings and accessories.

1.3 The system incorporates a primary and secondary means of weather resistance (first and second line of defence) against water penetration by separating the cladding from the external wall framing with a nominal 20 mm cavity.



Scope

2.1 The Ulltraclad® Cavity System has been appraised as an external wall cladding for buildings within the following scope:

- the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1; and,
- constructed with timber framing complying with the NZBC; and,
- with a risk score of 0-20, calculated in accordance with NZBC Acceptable Solution E2/AS1, Table 2; and,
- situated in NZS 3604 Wind Zones up to, and including 'Extra High'.

2.2 The Ulltraclad® Cavity System has also been appraised for weathertightness and structural wind loading when used as an external wall cladding system for buildings within the following scope:

- the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1 with regards to building height and floor plan area; and,
- constructed with timber framing complying with the NZBC; and,
- situated in specific design wind pressures up to a maximum design differential ultimate limit state (ULS) of 2.5 kPa.

2.3 The Ulltraclad® Cavity System must only be installed horizontally on vertical, flat surfaces.

2.4 The Ulltraclad® Cavity System is appraised for use with aluminium window and door joinery that is installed with vertical jambs and horizontal heads and sills. *(The Appraisal of the Ulltraclad® Cavity System relies on the joinery meeting the requirements of NZS 4211 for the relevant Wind Zone or design wind pressure.)*

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, the Ulltraclad® Cavity System if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet the following provisions of the NZBC:

Clause B1 STRUCTURE: Performance B1.3.1, B1.3.2 and B1.3.4. The Ulltraclad® Cavity System meets the requirements for loads arising from self-weight, earthquake, wind and impact [i.e. B1.3.3 (a), (f), (h) and (j)]. See Paragraphs 9.1 – 9.3.

Clause B2 DURABILITY: Performance B2.3.1 (b), 15 years and B2.3.2. The Ulltraclad® Cavity System meets these requirements. See Paragraphs 10.1 and 10.2.

Clause E2 EXTERNAL MOISTURE: Performance E2.3.2. The Ulltraclad® Cavity System meets this requirement. See Paragraphs 14.1 – 14.5.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. The Ulltraclad® Cavity System meets this requirement and will not present a health hazard to people.

3.2 This is an Appraisal of an **Alternative Solution** in terms of New Zealand Building Code compliance.

Technical Specification

4.1 System components and accessories for the Ulltraclad® Cavity System, which are supplied by Ullrich Aluminium Co Ltd, are:

Ulltraclad® Weatherboards

- Horizontally fixed Ulltraclad® weatherboards are produced in a rusticated weatherboard profile, with either a smooth (Standard), corrugated (Baby Corro) or grooved (Tee Board and Vertical Plank) face, in a bevelback weatherboard profile (Traditional), or a flat face with negative joint detail (Shadoline) and are powder coated on the exposed surfaces. When installed, the cladding is effectively 15 mm thick. Standard, Baby Corro and Vertical Plank weatherboards are available 190 mm wide, Tee Boards are available 150 mm wide, Traditional weatherboards are available 157 mm wide and Shadoline weatherboards are available 205 mm wide. The weatherboards are supplied in 5 m and 6 m lengths.
- Ulltraclad® weatherboards are manufactured from 6060 T5 grade aluminium alloy. The boards are extruded, cut to length and are then coated with a 100% polyester powder coating.

Accessories

- Cavity vent strip – a folded aluminium profile punched with 5 mm square holes in the bottom face to provide ventilation for the wall cavity and prevent the ingress of vermin. The cavity vent strip is available in 2.4 m lengths.
- Starter strips – extruded aluminium profiles used to locate and secure the bottom of the first course of weatherboards. The starter strips are powder coated and are available in 5 m lengths.
- External and internal corner moulding – extruded aluminium 90° two-piece internal corner mould and 90° two-piece external corner mould. The mouldings are powder coated and are available in 5 m lengths.
- Board jointer – extruded aluminium 'H' jointer for jointing lengths of Ulltraclad® weatherboard. The jointer is powder coated and is available in 5 m lengths.

- Board locator – an extruded aluminium locator used to locate the bottom edge and secure the top edge of individual weatherboard courses. The board locators are 50 mm long and are predrilled for fixing.
- Ulltraclad® head and jamb flashings – extruded aluminium to suit the window or door trim opening. The flashings are powder coated and are available in 5 m lengths.
- Inter-storey joint flashing – extruded aluminium. The flashing is powder coated and is available in 5 m lengths.
- Ulltraclad® weatherboard fixings – 50 x 3.3 mm AISI-302Cu stainless steel screws.

4.2 Accessories used with the Ulltraclad® Cavity System, which are supplied by the building contractor, are:

- Flexible wall underlay – building paper complying with NZBC Acceptable Solution E2/AS1 Table 23, or breather-type membranes covered by a valid BRANZ Appraisal for use as wall underlays.
- Flexible wall underlay support – polypropylene strap, 75 mm galvanised mesh, galvanised wire, or additional vertical battens for securing the flexible building underlay in place and preventing bulging of the bulk insulation into the drainage cavity. (Note: mesh and wire galvanising must comply with AS/NZS 4534.)
- Rigid wall underlay – Plywood or fibre cement sheet complying with NZBC Acceptable Solution E2/AS1 Table 23, or rigid sheathing covered by a valid BRANZ Appraisal for use as rigid air barrier systems.
- Flexible sill and jamb flashing tape – flexible flashing tapes complying with NZBC Acceptable Solution E2/AS1, Paragraph 4.3.11, or flexible flashing tapes covered by a valid BRANZ Appraisal for use around window and door joinery openings.
- Cavity battens – nominal 50 mm wide by 25 mm thick (minimum finished size of 45 mm wide by 18 mm thick) timber treated to Hazard Class H3.1 with non-copper based treatments.
- Separation strip – 50 mm wide strip of roof underlay complying with NZBC Acceptable Solution, Table 23.
- Cavity batten fixings – 40 x 2.5 mm flat head hot-dipped galvanised nails.
- Window corner soaker and parapet flashing – folded from aluminium.
- Head flashing – folded from aluminium to suit the window or door joinery opening.
- Inseal® 3109 tape – black, compressible, low density PVC foam. The foam is coated on one side with pressure sensitive acrylic adhesive and the other face is covered by a silicone release paper. The tape is 19 mm thick and is supplied in rolls 10 mm wide and 12 m long.
- Window and door trim cavity air seal – air seals complying with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.6, or self-expanding, moisture cure polyurethane foam air seals covered by a valid BRANZ Appraisal for use around window, door and other wall penetrations.
- Flexible sealant – sealant complying with NZBC Acceptable Solution E2/AS1, or sealant covered by a valid BRANZ Appraisal for use as a weather sealing sealant for exterior use.

Handling and Storage

5.1 Handling and storage of all materials supplied by Ullrich Aluminium Co Ltd or the building contractor, whether on site or off site, is under the control of the building contractor. Ulltraclad® weatherboards must be stacked flat, off the ground and supported on a level platform. They must be kept dry either by storing under cover or providing waterproof covers to the stack. Care must be taken to avoid damage to powder coated surfaces. Weatherboards must always be carried on edge.

5.2 Cavity battens and other accessories must be stored so they are kept clean, dry and undamaged. All accessories must be used within the maximum storage period recommended by the manufacturer.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for the Ulltraclad® Cavity System. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

Framing

Timber Treatment

7.1 Timber wall framing behind the Ulltraclad® Cavity System must be treated as required by NZBC Acceptable Solution B2/AS1.

Timber Framing

7.2 Timber framing must comply with NZS 3604 for buildings or parts of buildings within the scope limitations of NZS 3604. Buildings or parts of buildings outside the scope of NZS 3604 must be to a specific design in accordance with NZS 3603 and AS/NZS 1170. Where specific design is required, the framing must be of at least equivalent stiffness to the framing provisions of NZS 3604. In all cases studs must be at maximum 600 mm centres, with dwangs fitted flush between the studs at maximum 800 mm centres.

7.3 Timber wall framing and cavity battens must have a maximum moisture content of 24% at the time of the cladding application.

7.4 Additional framing will be required at soffits, internal and external corners and window and door openings for the support and fixing of Ulltraclad® weatherboards.

General

8.1 Punchings in the cavity vent strip provide a minimum ventilation opening area of 1000 mm² per lineal metre of wall in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.3(b).

8.2 The ground clearance to finished floor levels as set out in NZS 3604 must be adhered to at all times. At ground level paved surfaces, such as footpaths, must be kept clear of the bottom edge of the cladding system by a minimum of 100 mm, and unpaved surfaces by 175 mm in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Table 18.

8.3 At deck or low pitch roof/wall junctions, the bottom edge of the Ulltraclad® weatherboards must be kept clear of any adjacent surface, or above the top surface of any adjacent roof flashing by a minimum of 35 mm in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.3.

8.4 All external walls of buildings must have barriers to airflow in the form of interior linings with all joints stopped for wind zones up to and including Very High, and rigid underlays for buildings in the Extra High wind zone and specifically designed buildings up to 2.5 kPa design differential ULS wind pressure. Unlined gables and walls must incorporate a rigid sheathing or an air barrier which meets the requirements of NZBC Acceptable Solution E2/AS1, Table 23. For attached garages, wall underlays must be selected in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.3.4. Where rigid underlays are used, the cavity batten fixing lengths must be increased by a minimum of the thickness of the underlay.

8.5 Where penetrations through the Ulltraclad® Cavity System are wider than the cavity batten spacing, allowance must be made for airflow between adjacent cavities. A minimum 10 mm gap must be left between the bottom of the vertical cavity batten and the flashing to the opening.

8.6 Inter-storey drained joints must be constructed in accordance with the Technical Literature. Inter-storey drained joints must be provided to limit continuous cavities to the lesser of 2-storeys or 7 metres in height, in accordance with the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.9.4(b).

8.7 Where the Ulltraclad® Cavity System abuts other cladding systems, designers must detail the junction to meet their own requirements and the performance requirements of the NZBC. Details not included with the Technical Literature have not been assessed and are outside the scope of this Appraisal.

Structure

9.1 The mass of the Ulltraclad® Cavity System when installed on the wall is approximately 5 kg/m². The Ulltraclad® Cavity System is therefore considered a light wall cladding in terms of NZS 3604.

Impact Resistance

9.2 The Ulltraclad® Cavity System has good resistance to hard and soft body impacts likely to be encountered in normal residential use, although some chipping of the finish could occur. The likelihood of impact damage to the system when used in light commercial situations should be considered at the design stage, and appropriate protection such as the installation of bollards and barriers should be considered for vulnerable areas.

Wind Zones

9.3 The Ulltraclad® Cavity System is suitable for use in all Wind Zones of NZS 3604, up to, and including 'Extra High' where buildings are designed to meet the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 1.1, or up to design differential 2.5 kPa ULS wind pressure when the buildings are specifically designed.

Durability

Serviceable Life

10.1 The Ulltraclad® Cavity System is expected to have a serviceable life of at least 15 years provided the system is maintained in accordance with this Appraisal.

10.2 On exposure to the environment, the powder coating will gradually lose gloss and coloured coatings will slowly fade. A faster reduction in appearance and a reduction in serviceable life can be anticipated in severe industrial, geothermal, and marine exposures.

10.3 Microclimatic conditions, including geothermal hot spots, industrial contamination and corrosive atmospheres, and contamination from agricultural chemicals or fertilisers can convert mildly corrosive atmosphere into aggressive environments for fasteners. The fixing of Ulltraclad® weatherboards and accessories in areas subject to microclimatic conditions requires specific design in accordance with NZS 3604 Paragraph 4.2.4, and is outside the scope of this Appraisal.

Maintenance

11.1 Regular maintenance is essential for Ulltraclad® Cavity System installations to continue to meet the NZBC durability performance provision and to maximise their serviceable life.

11.2 Annual inspections must be made to ensure that all aspects of the cladding system, including flashings and any sealed joints remain in a weathertight condition. Any damaged areas or areas showing signs of deterioration which would allow water ingress, must be repaired immediately. Sealant and the like must be repaired in accordance with the sealant manufacturer's instructions. Regular cleaning (at least every 6 months) of the powder coating with water and a mild detergent is required to remove grime, dirt and organic growth, to maximise the life and appearance of the cladding. Repainting of the powder coating may be considered necessary after 10 years in order to restore the appearance of the cladding. Repainting must be carried out in accordance with the paint manufacturer's instructions for treatment of aged powder coated aluminium.

11.3 Minimum ground clearances as set out in this Appraisal must be maintained at all times during the life of the cladding. *(Failure to adhere to the minimum ground clearances given in this Appraisal and the Technical Literature will adversely affect the long term durability of the Ulltraclad® Cavity System.)*

Control of External Fire Spread

12.1 The Ulltraclad® Cavity System is suitable for use as an external wall cladding on all buildings in accordance with NZBC Acceptable Solution C/AS1 Part 7, Paragraph 7.11.2(a).

Outbreak of Fire

13.1 Ulltraclad® weatherboard is considered a non-combustible material and need not be separated from flues and chimneys. However, when used in conjunction with, or attached to heat sensitive materials, the heat sensitive material must be separated from chimneys and flues in accordance with the requirements of NZBC Acceptable Solution C/AS1 Part 9 for the protection of combustible materials.

External Moisture

14.1 The Ulltraclad® Cavity System, when installed in accordance with this Appraisal and the Technical Literature prevents the penetration of moisture that could cause undue dampness or damage to building elements.

14.2 The cavity must be sealed off from the roof and sub-floor space to meet compliance with NZBC Clause E2.3.5.

14.3 The Ulltraclad® Cavity System allows excess moisture present at the completion of construction to be dissipated without permanent damage to building elements to meet compliance with NZBC Clause E2.3.6.

14.4 The details given in the Technical Literature for weather sealing are based on the design principle of having a first and second line of defence against moisture entry for all joints, penetrations and junctions. The ingress of moisture must be excluded by detailing joinery and wall interfaces as shown in the Technical Literature. Weathertightness details that are developed by the designer are outside the scope of this Appraisal and are the responsibility of the designer for compliance with the NZBC.

14.5 The use of the Ulltraclad® Cavity System where there is a designed cavity drainage path for moisture that penetrates the cladding, does not reduce the requirement for junctions and penetrations to remain weather resistant.

Installation Information

Installation Skill Level Requirements

15.1 Installation of Ulltraclad® weatherboards and accessories supplied by Ullrich Aluminium Co Ltd and the building contractor must be completed in accordance with instructions given within the Ulltraclad® Cavity System Technical Literature and this Appraisal by tradespersons who have been trained by Ullrich Aluminium Co Ltd and have an understanding of cavity construction.

System Installation

Building Underlay and Flexible Sill and Jamb Tape Installation

17.1 The selected building underlay and flexible sill and jamb tape system must be installed by the building contractor in accordance with the underlay and tape manufacturer's instructions prior to the installation of the cavity battens and the rest of the Ulltraclad® Weatherboard Cavity System. Flexible wall underlay must be installed horizontally and be continuous around corners. Underlay must be lapped 75mm minimum at horizontal joints and 150mm minimum over studs at vertical joints. Generic rigid sheathing materials must be installed in accordance with NZBC Acceptable Solution E2/AS1 and be overlaid with a flexible wall underlay. Proprietary systems shall be installed in accordance with the manufacturer's instructions. Particular attention must be paid to the installation of the building underlay and sill and jamb tapes around window and door openings to ensure a continuous seal is achieved and all exposed wall framing in the opening is protected.

Cavity Battens

16.2 Cavity battens must be installed over the building wrap to the wall framing at maximum 600 mm centres where the studs are at maximum 600 mm centres or at 400 mm centres where the studs are at 400 mm centres. The battens must be fixed in place with 40 x 2.5 mm hot-dipped galvanised flat head nails at maximum 800 mm centres.

16.3 Where studs are at greater than 450 mm centres and a flexible wall underlay is being used, a wall underlay support must be installed over the underlay at maximum 300 mm centres horizontally to prevent the wrap bulging into the cavity space when bulk insulation is installed in the wall frame cavity.

Aluminium Joinery Installation

16.4 Aluminium joinery and associated head flashings must be installed by the building contractor in accordance with the Technical Literature. A 7.5 – 10 mm nominal gap must be left between the joinery reveal and the wall framing so a PEF rod and air seal can be installed after the joinery has been secured in place.

Ultraclad® Aluminium Weatherboard Installation

16.5 Ultraclad® weatherboards may be cut on site by power saw fitted with an aluminium cutting blade. Holes and cut-outs may be formed by drilling a number of holes around the perimeter of the opening required, or by using a holesaw suitable for cutting aluminium. When cutting the weatherboards on site, a strip of masking tape must be applied to each side of the cut line to prevent the weatherboard finish from being damaged.

16.6 Ultraclad® weatherboards must be installed starting at the bottom of the wall. The first course of weatherboards must overhang the bottom plate by a minimum of 50 mm.

16.7 Before the weatherboards and starter strip are installed, the corner mouldings must be fixed in place. The corner mouldings must be continuous in length from the underside of the first weatherboard course to the soffit or top of the wall.

16.8 When the wall being clad is longer than 6 m, a board jointer must be fixed in place over a cavity batten directly over a stud. The jointer must be fixed plumb and must be continuous from the underside of the first weatherboard course to the soffit or top of the wall.

16.9 The starter strip must be fixed through the cavity battens to the wall framing behind the first course of weatherboards. The starter strip for the Ultraclad® weatherboards must be fixed level and a 20 mm gap must be maintained between each end of the starter strip and the corner moulds or board jointer. The starter strip for the Vertical Plank must be fixed level and 3 mm diameter holes must be drilled in the base of the channel at 600 mm centres to allow for drainage.

16.10 Ultraclad® weatherboards are cut to length allowing a 4 mm gap at each end of the board for expansion. The first course of Standard, Baby Corro, Tee Board, Traditional and Shadoline weatherboards must be locked into the tongue of the starter strip and must then be secured at the top of the board with board locators fixed through the cavity battens to the stud. The first course of Vertical Plank is a half board and is fitted into the Vertical Plank starter strip channel. The top of the board is fixed through the board upstand, through the cavity battens to the stud.

16.11 Subsequent courses of Standard, Baby Corro, Tee Board, Traditional and Shadoline weatherboards must be installed over the tongue of the board locator from the course below, and must be secured at the top of the board with locators fixed through the cavity batten to the stud at maximum 600 mm centres. Subsequent courses of Vertical Plank must be installed by inserting the ball section of the board into the socket of the previous board, and must be secured at the top by fixing through the board upstand, through the cavity battens to the stud at maximum 600 mm centres.

16.12 Board fixing is carried out using 50 x 3.3 mm stainless steel screws.

16.13 Window and door joinery head and jamb flashings must be installed in accordance with the Technical Literature.

Finishing

16.14 The Ultraclad® Cavity System is pre-finished and does not require painting at the completion of installation. Touch up of scratches and the like must be completed in accordance with the instructions of Ullrich Aluminium Co Ltd.

Health and Safety

17.1 Hearing and eye protection must be worn while cutting Ultraclad® weatherboards and accessories.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

18.1 The following testing on the Ultraclad® Cavity System has been completed by BRANZ:

- The Ultraclad® Cavity System has been tested to the version of E2/VM1 as contained within NZBC Clause E2, Amendment 5, August 2011. BRANZ expert opinion on NZBC E2 code compliance for the Ultraclad® Cavity System was based on testing and evaluation of all details within the scope and as stated within this Appraisal. The testing assessed the performance of the foundation detail, window head, jamb and sill details, meter box head, jamb and sill details, vertical board joints, internal and external corners. In addition to the weathertightness test, the details contained within the Technical Literature have been reviewed, and an opinion has been given by BRANZ technical experts that the system will meet the performance levels of Acceptable Solution E2/AS1 for drained cavity claddings.
- Uniform wind face load tests to simulate wind pressures on Ultraclad® Standard weatherboard were carried out by BRANZ, and the results were used in assessing the Ultraclad® Cavity System.
- A racking test was completed to examine the performance of the Ultraclad® Cavity System when the system was subjected to both serviceability and ultimate level seismic racking deflections, taken to be ± 8 mm and ± 36 mm respectively. The system did not show signs of damage for the entire test program.

Other Investigations

19.1 Structural and durability opinions have been provided by BRANZ technical experts.

19.2 Site visits have been carried out by BRANZ to assess the practicability of installation, and to examine completed installations.

19.3 The Technical Literature for the Ultraclad® Cavity System has been examined by BRANZ and found to be satisfactory.

Quality

20.1 The manufacture of Ultraclad® weatherboards has been examined by BRANZ, and details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory.

20.2 The quality of materials, components and accessories supplied by Ullrich Aluminium Co Ltd is the responsibility of Ullrich Aluminium Co Ltd. The quality control system of Ullexco (a division of Ullrich Aluminium Co Ltd) has been assessed and registered as meeting the requirements of ISO 9001: 2008.

20.3 Quality of installation on site of components and accessories supplied by Ullrich Aluminium Co Ltd and the building contractor is the responsibility of the installer.

20.4 Designers are responsible for the building design, and building contractors are responsible for the quality of installation of framing systems and joinery, building wraps, flashing tapes, airseals, joinery head flashings and cavity battens in accordance with the instructions of Ullrich Aluminium Co Ltd.

20.5 Sub-trades are responsible for installation of penetrations, flashings etc that are relevant to their trade in accordance with the Ultraclad® Cavity System Technical Literature.

20.6 Building owners are responsible for the maintenance of the Ulltraclad® Cavity System in accordance with the instructions of Ullrich Aluminium Co Ltd.

Sources of Information

- AS/NZS 1170: 2002 Structural design actions.
- NZS 3602: 2003 Timber and wood-based products for use in building.
- NZS 3603: 1993 Timber Structures Standard
- NZS 3604: 2011 Timber-framed buildings.
- NZS 4211: 2008 Specification for performance of windows.
- Compliance Document for New Zealand Building Code External Moisture Clause E2, Department of Building and Housing, Third Edition July 2005 (Amendment 5, 1 August 2011).
- New Zealand Building Code Handbook Department of Building and Housing, Third Edition (Amendment 12, 10 October 2011).
- The Building Regulations 1992.

Reissue Note. 2 October 2012

The Ulltraclad® Cavity System has been re-appraised to update all Basis-of-Appraisal information, including retesting to the version of E2/VM1 as contained within NZBC Clause E2, Amendment 5, August 2011. This Appraisal replaces Appraisal No. 487(2006) issued 21 December 2006.



BRANZ

In the opinion of BRANZ, Ulltraclad® Cavity System is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to Ullrich Aluminium Co Ltd, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the technical literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. Ullrich Aluminium Co Ltd:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions.
 - d) Warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by Ullrich Aluminium Co Ltd.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to Ullrich Aluminium Co Ltd or any third party.

For BRANZ

P Burghout
Chief Executive

Date of issue: 2 October 2012